



ROGERS STATE
UNIVERSITY
PHYSICAL PLANT

ROGERS STATE UNIVERSITY
1701 W. WILL ROGES BLVD.
CLAREMORE, OK 74017

RE: Addendum No. 1

PROJECT: Request for Bid – University Housing “UVA” HVAC Replacement
RFB 2425-11

DATE OF REQUEST FOR BID: January 31, 2025

DATE OF ADDENDUM ISSUE: February 22, 2025

THIS SCOPE OF WORK IS HEREBY MADE PART OF THE CONTRACT AS THOUGH IT HAD BEEN INCLUDED ORIGINALLY THEREIN, AND IT SHALL SUPERSEDE ANYTHING CONTAINED IN THE CONTRACT WITH WHICH IT MIGHT CONFLICT.

CLARIFICATIONS:

Item No. 1 – Do not provide or install overflow devices for the six (6) common area units.

Item No. 2 – There are only 26 apartment units being installed. There is a notation within the specs that indicates to 27, which is not correct.

ADDITIONS:

Item No.1 – Contractor to provide and install new overflow devices at the 26 apartment units.

Item No. 2- Contractor replace all 26 condensers pads. Approved pad are: 30 X 30 CLADLITE PAD 3" , Locke Part #: L0660,Mfg. Part #: 3030-3 Manufacturer: DIVERSITECH CORP.

CHANGE:

Item No. 1 – Maximize the duct size, using all available space of the existing framing, at second floor north unit, serving the server closet. Duct to be constructed utilizing duct board.

END OF ADDENDUM